

Elm St. Sanitary Sewer Bid – Columbia Township (Hamilton County)

July 23, 2024

Bid Posted

August 15, 2024

11:00a Bid Opening

Update #1 – Q&As

August 1, 2024

1. Do I need to submit a bid bond? I couldn't find anywhere if one was needed or for how much.

I do not see where a bid bond is required, just a performance bond.

2. Do you have the engineer's estimate for this?

It is stated in the bid packet that an engineer's estimate is not included.

3. Surveying for project is provided and paid for by owner?

Surveying is part of the bid and is the contractor's responsibility.

4. Trench restoration is only in the area of trench and not full width of street? No grind and pave?

Correct - per Roadway Trench Restoration Detail provided.

5. Fees paid by Township or others?

Street opening permit –Township will not require the contractor to apply for the street opening permit because it is a Township project on a Township road.

MSD inspection fees - The Project Overview states the sewer will need to be inspected and accepted by MSDGC, but it does not state who is responsible for the inspection fees. The MDDGC fees are the responsibility of the contractor.

Other permits and associated fees – Bid states that the Township obtained OEPA approval and all other permits are the responsibility of the contractor.

- Bid Update #1 End -